

## Heat-ON Ltd

1618 Sofia, blvd. Bratia Buxton 40  
tel: (+359) 2 955 53 84  
e-mail: office@zonagas.bg

## Annotation

**Regarding:** FprEN 17175 regulation, Gas-fired thermal stations with a thermal output bigger than 35 kW: Notification: 2019/0263 / I

Dear All,

This Italian regulation indicates a maximum surface temperature of the radiant strip piping up to 300 °C, which does not correspond to the maximum surface temperature of the pipe contained in the new FprEN standard 17175 (up to 400 °C).

As the new FprEN 17175 standard was recently voted at CEN level, we believe that even the new Italian technical standard on fire safety, the surface temperature of radiant tubes should be corrected to 400 °C.

The difference of the surface temperature of 400 °C of the new standard and the surface temperature of the new Italian technical fire safety standard of 300 °C would lead to a difference between European and Italian regulation. This difference would clearly lead to a limitation of the free circulation of goods on the Italian market opposing the basic principle of the European Economic Community (EEC) for a free movement of goods.

This also applies to the information procedure in the field of technical regulations (Directive (EU) 2015/1535).

Sofia, 08.08.201

Kind Regards:...

*Talk*  
  
Borislav Momchilov

/General manager/